### **OWNER'S MANUAL**





Series: PFSWCPC75

3/4 HP • 1750 RPM • 60 Hz Submersible Sewage Pump



## **General Safety Information**

Before installation, read the following instructions carefully. Failure to follow instruction and Safety information could cause serious bodily injury, death and/or property damage. Each Power-Flo pump is individually factory tested to insure proper performance. Closely following these instructions will eliminate potential operating problems, assuring years of trouble-free service.

IMPORTANT - Power-Flo Pumps and Systems is not responsible for losses, injury or death resulting from failure to observe these safety precautions, misuse, abuse or misapplication of pumps or equipment.



Do not pump flammable or explosive liquids such as oil, gasoline, kerosene, ethanol, etc. Do not use in the presence

of flammable or explosive vapors. Using this pump with or near flammable liquids can cause an explosion or fire, resulting in property damage, serious personal injury, and/or death.

**AWARNING** 

**ALWAYS** disconnect the power to the pump


before servicing.

**A** CAUTION

Release all pressure and drain all water from the

system before servicing any component.

A DANGER



operation. The motor is designed to operate at high temperatures. Do not disassemble the motor housing.

A DANGER

Do not handle the pump or pump motor

with wet hands or when standing on a wet or damp surface, or in water before disconnect the power. **AWARNING** 

Secure the discharge line before starting the

pump. An unsecured discharge line will whip, possibly causing personal injury, and/or property damage.

**▲ DANGER** 

Extension cords may not deliver sufficient

voltage to the pump motor. Extension cords present a life threatening safety hazard if

the insulation becomes damaged or the connection ends fall into water. The use of an extension cord to power this pump is not permitted.

**AWARNING** 

Wear safety goggles at all times when

working with pumps.

 $\mathbf{A}\mathbf{WARNING}$ 

These units are designed for use on 115 volts or

230 volts (single phase), 60 Hz, and equipped with an approved 3-conductor cord and 3-prong grounded plug. Do not remove the ground pin under any circumstances. The 3-prong plug must be directly inserted into a properly installed and grounded 3-prong, grounding-type receptacle. Do not use this pump with a 2-prong wall outlet. Replace the 2-prong outlet with a properly grounded 3-prong receptacle (a GFCI outlet) installed in accordance with the National Electrical Code and local codes and ordinances. All wiring should be performed by a qualified electrician.

**AWARNING** 

Protect the electrical cord from sharp

objects, hot surfaces, oil, and chemicals. Avoid kinking the cord. Do not use damaged or worn cords.

**AWARNING** 

Failure to comply with the instruction and

designed operation of this unit may void the warranty. *ATTEMPTING TO USE A DAMAGED PUMP* can result in property damage, serious personal injury, and/or death.

**AWARNING** 

Ensure that the electrical circuit to

the pump is protected by a 20 Amp - for 115V or 10 Amp for 230V, fuse or circuit breaker.

**AWARNING** 

Do not lift the pump by the power cord.

**A** CAUTION

Know the pump and its applications,

limitations, and potential hazards.

**IMPORTANT!** - Secure the pump to a solid base. This will aid in keeping the pump in a vertical orientation. This is critical in keeping the pump operating at maximum efficiency. It will also help prevent the pump from clogging resulting in premature failure.

**IMPORTANT!** - Periodically inspect the pump and system components to ensure the pump suction screen is free of mud, sand, and debris. Disconnect the pump from the power supply before inspecting.

**AWARNING** 

Follow all local electrical and safety

codes, along with the National Electrical Code (NEC). In addition, all Occupational Safety and Health Administration (OSHA) guidelines must be followed.

**AWARNING** 

The motor of this pump has a thermal protector

that will trip if the motor becomes too hot. The protector will reset itself once the motor cools down and an acceptable temperature has been reached. The pump may start unexpectedly if it is plugged in.

**▲** CAUTION

Ensure the electrical power source is

adequate for the requirements of the pump.

**IMPORTANT!** - This pump is made of highstrength, corrosion-resistant materials. It will provide trouble-free service for a long time when properly installed, maintained, and used. However, inadequate electrical power to the pump, dirt, or debris may cause the pump to fail.



Power-Flo is a registered trademark of Power-Flo Technologies Inc.
 Alteration Rights Reserved. 3/15, 8/15

# **Specifications**

## **Features:**

Submersible sewage pump designed for typical raw sewage and typical septic tank/effluent applications.

• DISCHARGE: 2" NPT Male, Vertical ● LIQUID TEMPERATURE: 32°-131°F • MOTOR HOUSING: Cast Iron.

• **IMPELLER:** Corrosion-resistant, reinforced Thermoplastic

• PUMP BASE: Cast Iron. SHAFT: Stainless Steel HARDWARE: Stainless steel

GASKET: Rubber

• **SEAL:** Single mechanical, Carbon/Ceramic/Stainless Steel


• UPPER BEARING: Single row, ball, oil lubricated • LOWER BEARING: Single row, ball, oil lubricated

• POWER CORD: 115V - SJTW, 16AWG/3C Cord with plug, 230V - SJTW, 18AWG/3C Cord with plug

• MOTOR: Energy efficient Permanent Split Capacitor (PSC), Oil filled, Class B insulation, Continuous duty (water depth must be at least 6" to prevent motor from overheating), Auto reset thermal overload protector, Circuit requirments; 115V - 20 AMPS, 230V - 10 AMPS.

• LEVEL CONTROL: Vertical, Mechatronic, Normally Open (N/O), Reinforced thermoplastic, 115V-SJTW 16AWG/3C, 230V-SJTW 18AWG/3C, 10 Ft. cord with, Piggy-back plug, On-Off points are adjusteable, Attaches to discharge piping.

WARRANTY: 3 year



HEAD in Ft	0 Ft	5 Ft	10 Ft	15 Ft	Max Lift	Max Pressure	
FLOW Gallon/Minute	145	125	100	65	20 Ft	0 0 nci	
FLOW Gallon/Hour	8700	7500	6000	3900	20 FL	8.8 psi	

PF	TYPE U, SP, SW	Motor Housing P, C	Impeller Type P, C	Suction Plate Type P, C	Motor HP 25, 33, 50, 75, 1	30	50	Voltage 1 or 2	Float Switch Type M, F, T	Cord Length 10, 15
		P = Plastic C = Cast Iron	P = Plastic C = Cast Iron	P = Plastic C = Cast Iron	25 = 1/4 HP 33 = 1/3 HP 50 = 1/2 HP 75 = 3/4 HP 1 = 1 HP	Shut Off Head (ft)	Max Flow (Gal)	1 = 115 V 2 = 230V	M = Manual F = Fixed Vertical T = Tethered	10 Ft 25 Ft


EXAMPLE: PFSPCPC3330501T10 - Power-Flo Pumps - Sump Pump - Cast Iron Motor Housing - Plastic Impeller - Cast Iron Suction Plate - 1/3HP - 30"Shut Off Head - 50GPM Max Flow - 115 Volt - Tethered Float - 10'Cord




**Submersible Sewage Pump** 2" Discharge, 2" Spherical Solids **Vertical Float** 




# **Performance & Dimensions**





# Models: PFSWCPC75201451F10 PFSWCPC75201452F10





# **Specifications**

## **Features:**

Submersible sewage pump designed for typical raw sewage and typical septic tank/effluent applications.

DISCHARGE: 2" NPT Male, Vertical
 LIQUID TEMPERATURE: 32°-131°F

• MOTOR HOUSING: Cast Iron.

• **IMPELLER:** Corrosion-resistant, reinforced Thermoplastic

PUMP BASE: Cast Iron.
 SHAFT: Stainless Steel
 HARDWARE: Stainless steel

• GASKET: Rubber

• **SEAL:** Single mechanical, Carbon/Ceramic/Stainless Steel


UPPER BEARING: Single row, ball, oil lubricated
 LOWER BEARING: Single row, ball, oil lubricated

 POWER CORD: 115V - SJTW, 16AWG/3C Cord with plug, 230V - SJTW, 18AWG/3C Cord with plug

MOTOR: Energy efficient Permanent Split Capacitor (PSC), Oil filled, Class B insulation, Continuous duty (water depth must be at least 6" to prevent motor from overheating), Auto reset thermal overload protector, Circuit requirments; 115V - 20 AMPS, 230V - 10 AMPS.

 LEVEL CONTROL: Wide Angle Tethered, Mechanical, Normally Open (N/O), Reinforced thermoplastic,
 115V-SJOW 16AWG/2C, 230V-SJOW 18AWG/2C, 10 Ft. cord w/Piggy-back plug, On point - 16.5", Off point - 8.7"

● WARRANTY: 3 year



HEAD in Ft	0 Ft	5 Ft	10 Ft	15 Ft	Max Lift	Max Pressure
FLOW Gallon/Minute	145	125	100	65	20 E+	0.0
FLOW Gallon/Hour	8700	7500	6000	3900	20 Ft	8.8 psi


PF	TYPE U, SP, SW	Motor Housing P, C	Impeller Type P, C	Suction Plate Type P, C	Motor HP 25, 33, 50, 75, 1	30	50	Voltage 1 or 2	Float Switch Type M, F, T	Cord Length 10, 15
Power-Flo		C = Cast Iron	P = Plastic C = Cast Iron	P = Plastic C = Cast Iron	25 = 1/4 HP 33 = 1/3 HP 50 = 1/2 HP 75 = 3/4 HP 1 = 1 HP	Shut Off Head (ft)	Max Flow (Gal)		M = Manual F = Fixed Vertical T = Tethered	10 Ft 25 Ft


**EXAMPLE:** PFSPCPC3330501T10 - Power-Flo Pumps - Sump Pump - Cast Iron Motor Housing - Plastic Impeller - Cast Iron Suction Plate - 1/3HP - 30°Shut Off Head - 50GPM Max Flow - 115 Volt - Tethered Float - 10°Cord



# Submersible Sewage Pump 2" Discharge, 2" Spherical Solids Wide Angle Tethered Float

# **Performance & Dimensions**






## **Pre-Installation**

#### **APPLICATION**


This submersible sewage pumps and designed for pumping sewage, effluent, wastewater or flooded water with up to 2 inch solids.

The pump is built with overload thermal protections and auto reset. The pump is equipped with a 3-prong grounding-type power cord and tethered or vertical float switch. This pump operates automatically. Ball bearings on motor shafts never need lubrication.

## **TOOLS REQUIRED**



## **MATERIALS REQUIRED** (NOT INCLUDED)



Minimum Sump basin: 18 in. diameter, 30 in. depth

## Installation

#### INSTALLATION

**NOTICE:** Install pump on a hard, level surface (cement, asphalt, etc.). Never place pump directly on earth, clay or gravel surfaces.

Piping – (2" or Less Solids)

In any case, piping must not be smaller than pump discharge. When installed in a sewage system, pipe must be capable of handling semi-solids of at least 2" diameter. The rate of flow in the discharge pipe must keep any solids present in suspension in the fluid. To meet minimum flow requirements, the minimum pipe size is 2".

Use a 2" swing check valve in pump discharge to prevent backflow of liquid into sump basin. Check valve should be a free flow valve that will easily pass solids.

**NOTICE:** For best performance of check valve when handling solids, do not install it with discharge angled more than 45° above the horizontal. Do not install check valve in a vertical position as solids may settle in valve and prevent opening on startup. Drill a 3/16" hole in discharge pipe about 1"-2" above pump discharge connection (but below check valve) to prevent airlocking the pump.

#### **Electrical**



WARNING: Risk of electric shock. Can shock, burn or kill. When installing, operating, or servicing this pump, follow safety instructions listed below.

- Step 1. DO NOT splice the electrical power cord.
- Step 2. DO NOT allow electrical cord plug to be submerged.
- Step 3. DO NOT use extension cords. They are a fire hazard and can reduce voltage sufficiently to prevent pumping and/or damage motor.
- Step 4. DO NOT handle or service pump while it is connected to power supply.
- Step 5. DO NOT remove grounding prong from plug or modify plug. To protect against electrical shock, the power cord is a three-wire conductor and includes a 3-prong grounded plug. Plug pump into a 3-wire, grounded, grounding type receptacle. Connect pump according to electrical codes that apply.


For automatic operation, plug pump into an automatic float switch or pump controller. Pump will run continuously when plugged directly into an electrical outlet. Connect or wire pump to an individual branch circuit with no other outlets or equipment in the circuit.


**AUTOMATIC** - Plug the pump power cord plug into the piggy-back switch plug outlet, and then plug the switch plug into a 115V for 115 V (see Figure 1) or 230V for 230V (see Figure 2) GFCI power outlet for automatic operation. The pump will start operating if the float switch moves over the top of the pump. The water will be pumped out. When the water lowers to a certain level, the float switch will turn off the pump.

**MANUAL** - Plug the pump power cord plug into a 115V for 115 V (see Figure 1) or 230V for 230V (see Figure 2) GFCI power outlet directly for manual operation. Pump will start operating once it is pluged into the GFCI outlet and water will drain out. When water is drained out, you must unplug the pump.



## **Operation**





Size fuses or circuit breakers according to chart below.

#### **Fuse Data**

MODEL	НР	VOLTAGE	Individual Branch Cercuit Required (Amps)	
PFSWCPC75201451F10		115	20	
PFSWCPC75201451T10	3/4	115	20	
PFSWCPC75201452F10	3/4	220	10	
PFSWCPC75201452T10		230	10	

#### **OPERATION**

**NOTICE:** Do not allow pump to run in a dry sump. It will void the warranty and may damage the pump.

An automatic overload protector in the motor will protect motor from burning out due to overheating / overloading. When motor cools down, overload protector will automatically reset and start motor. If overload trips frequently, check for cause. It could be a stuck impeller, wrong/low voltage, or electrical failure in motor. If an electrical failure in the motor is suspected, have it serviced by a competent repairman.

Pump is permanently lubricated. No oiling or greasing is required.




## Operation

#### **General**



WARNING: Risk of electric shock. Can shock, burn or kill.

- Do not lift pump by power cord.
- Before removing pump from basin for service, always disconnect electrical power to pump and control switch.
- Submerge pump in a disinfectant solution (bleach) for at least one hour before disassembling pump.
- Put the pump upside down.
  - **Note:** Pump is oil filled, to void the oil leakage don't incline the pump.
- Unscrew the stainless screws, and remove the volute/gasket.
- Use a flathead screwdriver to hold the shaft, then turn the impeller counterclockwise to release the impeller.
- Remove debris from around the shaft and on/under the impeller.
- Reassemble the pump.





# Troubleshooting

Symptom	Possible Cause(s)	Corrective Action
	1. The fuse is blow.	1. Replace the fuse
	2. The breaker is tripped.	2. Reset the breaker
	3. The plug is disconnected.	3. Secure the plug
	4. The plug is corroded.	4. Clean the plug prongs
	5. Thermal overload.	5. Unplug for 30 minutes, then plug in
	6. Clogged impeller.	6. Remove the blockage
Pump does not start or run	7. Motor failed	7. Replace pump
	8. Float failed	8. Replace switch
	9. Water level too low	9. Pump will not turn on unless water
		level is over the pump cover and the
	10. Tangled switch	float switch turns upside down  10. Reposition the pump and make
	10. Tangieu switch	sure switch moves freely
	1. Debris caught in impeller or pipe	1. Clean out debris.
Division amounted by the course little and a	2. Check valve stuck or installed backward	2. Inspect check valve and make sure
Pump operates but pumps little or no water	3. Anti-airlock hole blocked	it's properly installed 3. Remove the blockage
water	4. Impeller loose on shaft	4. Reassemble impeller
	5. Impeller broken	5. Replace impeller
	·	<del>                                     </del>
D	Backflow of water from piping, check	1. Replace check valve
Pump starts and stops too often	valve leaking	a Budana Mila
	2. Float switch failed	2. Replace switch
Pump will not shut off	1. Defective float switch	1. Replace switch
i dinp will not shut on	2. Float obstruction	2. Remove obstruction

**NOTE:** Power-Flo Pumps & Systems assumes no responsibility for damage or injury due to disassembly in the field. Disassembly of the pumps or supplied accessories other than at Power-Flo Pumps & Systems or its authorized service centers, automatically voids warranty.

2. Float obstruction



2. Remove obstruction

## **3 YEAR WARRANTY**

Manufacturer warrants, to the purchaser and subsequent owner during the warranty period, new pump product to be free from defects in material and workmanship under normal use and service, when properly used and maintained, for a period of 3 years from date of sale. The date of sale shall be determined by a dated sales receipt noting the model and serial number of the pump. The dated sales receipt must accompany the returned pump if the date of the return is more than 3 years from the date of manufacturer. Product will be repaired, replaced or remanufactured at Manufacturer's option. No allowance will be made for shipping charges, damages, labor or other charges that may occur due to product failure, repair or replacement. This warranty does not apply to and there shall be no warranty for any material or product that has been disassembled without prior approval of Manufacturer, subjected to misuse, misapplication, neglect, alteration, accident or act of God; that has not been installed, operated or maintained in accordance with Manufacturer's installation instructions; that has been exposed to outside substances including but not limited to the following: sand, gravel, cement, mud, tar, hydrocarbons, hydrocarbon derivatives (oil, gasoline, solvents, etc.), or other abrasive or corrosive substances, wash towels or feminine sanitary products, etc. in all pumping applications. The warranty set out in the paragraph above is in lieu of all other warranties expressed or implied; and we do not authorize any representative or other person to assume for us any other liability in connection with our products.

Contact Manufacturer at: 1-877-24PUMPS or www.powerflopumps.com, Attention: Customer Service Department, to obtain any needed repair or replacement of part(s) or additional information pertaining to our warranty. MANUFACTURER EXPRESSLY DISCLAIMS LIABILITY FOR SPECIAL, CONSEQUENTIAL OR INCIDENTAL DAMAGES OR BREACH OF EXPRESSED OR IMPLIED WARRANTY; AND ANY IMPLIED WARRANTY OF FITNESS FOR A PARTICULAR PURPOSE AND OF MERCHANTABILITY SHALL BE LIMITED TO THE DURATION OF THE EXPRESSED WARRANTY.

Some states do not allow limitations on the duration of an implied warranty, so the above limitation may not apply to you. Some states do not allow the exclusion or limitation of incidental or con sequential damages, so the above limitation or exclusion may not apply to you. This warranty gives you specific legal rights and you may also have other rights which vary from state to state.

