



## INSTALLATION AND OPERATION INSTRUCTIONS

**OWNER / INSTALLER:** For your safety this manual must be carefully and thoroughly read and understood before installing, operating or servicing this heater.

### INFRARED RADIANT TUBE HEATER Single Stage Pull Through System (Negative Pressure)

#### Models:

**SIS SERIES:** (50, 75, 100, 125, 150, 175) – N5/L5

**SIU SERIES:** (50, 75, 100, 125, 150, 175) – N5/L5

**!INSTALLER:** This manual is the property of the owner. Please present this manual to the owner when you leave the job site.

**▲ WARNING:** Improper installation, adjustment, alteration, service, or maintenance can cause property damage, injury or death. Read the installation, operation and maintenance instructions thoroughly before installing or servicing this equipment.

#### IF YOU SMELL GAS:

- ! DO NOT** try to light any appliance.
- ! DO NOT** touch any electrical switch; **DO NOT** use any telephone in your building.
- ! IMMEDIATELY** call your gas supplier from a neighbor's telephone. Follow the gas supplier's instructions. If you cannot reach your gas supplier, call the fire department.

#### FOR YOUR SAFETY

**DO NOT** store or use gasoline or other flammable vapors and liquids in the vicinity of this or any other appliance.

**!IMPORTANT: SAVE THIS MANUAL FOR FUTURE REFERENCE.**

#### **SUNSTAR HEATING PRODUCTS, INC.**

Post Office Box 36271 (28236) • 306 West Tremont Avenue (28203) • Charlotte, North Carolina  
Phone (704) 372-3486 • Fax (704) 332-5843 • [www.sunstarheaters.com](http://www.sunstarheaters.com) • email: [info@sunstarheaters.com](mailto:info@sunstarheaters.com)

## TABLE OF CONTENTS

| <u>SECTION</u> | <u>DESCRIPTION</u>                                   | <u>PAGE</u> |
|----------------|------------------------------------------------------|-------------|
| 1.0)           | Safety .....                                         | 2           |
| 2.0)           | Installer Responsibility .....                       | 2           |
| 3.0)           | General Information.....                             | 2           |
| 4.0)           | Minimum Clearances to Combustibles.....              | 4           |
| 5.0)           | Specifications.....                                  | 5           |
| 6.0)           | Packing List.....                                    | 5           |
| 6.1)           | Accessory Packages .....                             | 8           |
| 7.0)           | Typical Layouts .....                                | 10          |
| 8.0)           | Dimensions – SIS Series.....                         | 11          |
| 8.1)           | Dimensions – SIU Series.....                         | 12          |
| 8.2)           | Heater Assembly / Joining of Tube Sections .....     | 13          |
| 9.0)           | Typical Suspension Methods .....                     | 15          |
| 10.0)          | Assembly of Tube Sections.....                       | 16          |
| 10.1)          | Assembly of Extension Sections .....                 | 17          |
| 10.2)          | Adding Reflectors.....                               | 18          |
| 10.3)          | Adding Optional 90° Elbow (SIS Only).....            | 19          |
| 10.4)          | Adding Optional Corner Reflector (SIS Only).....     | 20          |
| 10.5)          | Adding 180° U-Bend (SIU Only) .....                  | 20          |
| 10.6)          | Adding Optional U-Bend Reflector (SIU Only).....     | 21          |
| 11.0)          | Attaching Control Box Assembly.....                  | 22          |
| 12.0)          | Attaching Draft Inducer Assembly.....                | 23          |
| 13.0)          | Multiple Hanging & Draft Inducer Positions .....     | 24          |
| 14.0)          | Gas Connections and Regulations.....                 | 25          |
| 15.0)          | Instructions for Pressure Test Gauge Connection..... | 27          |
| 16.0)          | Electrical Connections .....                         | 28          |
| 17.0)          | Venting.....                                         | 32          |
| 18.0)          | Air for Combustion .....                             | 36          |
| 18.1)          | Direct Outside Air for Combustion .....              | 36          |
| 19.0)          | Lighting and Shutdown Instructions.....              | 38          |
| 20.0)          | Sequence of Operation.....                           | 38          |
| 21.0)          | Control Component Location.....                      | 39          |
| 22.0)          | Cleaning and Annual Maintenance .....                | 40          |
| 23.0)          | Troubleshooting Guide.....                           | 41          |
| 24.0)          | Replacing Parts .....                                | 44          |
| 24.1)          | Removing Spark Electrode .....                       | 44          |
| 24.2)          | Removing Main Burner and Gas Valve .....             | 45          |
| 24.3)          | Air Switch Pressure Check.....                       | 46          |
| 24.4)          | Ignition System Checks.....                          | 46          |
| 24.5)          | Motor and Blower Wheel Check.....                    | 47          |
| 25.0)          | Installation Data .....                              | 47          |
| 26.0)          | Replacement Parts Guide.....                         | 48          |

This heater complies with ANSI Z83.20 (current standard) and CSA 2.34. Copies of the National Fuel Gas Code (ANSI Z223.1-latest edition) are available from the CSA at 8501 East Pleasant Valley Road, Cleveland, Ohio 44131 or 55 Scarsdale Road, Don Mills, Ontario M3B 2R3. All NFPA codes are available from the National Fire Protection Association, Batterymarch Park, Quincy, Massachusetts 02269.

## 1.0) SAFETY

This heater is a self-contained infrared radiant tube heater. Safety information required during installation and operation of this heater is provided in this manual and the labels on the product. The installation, service and maintenance of this heater must be performed by a contractor qualified in the installation and service of gas fired heating equipment.

All personnel in contact with the heater must read and understand all safety information, instructions and labels before operation. The following symbols will be used in this manual to indicate important safety information.

### **WARNING**

**Warning** instructions must be followed to prevent or avoid hazards which may cause serious injury, property damage or death.

### **CAUTION**

**Caution** instructions must be followed to prevent incorrect operation or installation of the heater which may cause minor injury or property damage.

## 2.0) INSTALLER RESPONSIBILITY

The installer is responsible for the following:

- The heater and venting, as well as electrical and gas supplies must be installed in accordance with these installation instructions and any applicable codes and regulations.
- Every heater shall be located with respect to building construction and other equipment so as to permit access to the heater.
- Each installer must follow the clearances to combustible materials for the heaters.
- Install the heater so that the supports and hangers are correctly spaced in accordance with these instructions. The heater must be supported by materials having a working load limit of at least 115lbs.
- Supply the owner with a copy of these Installation and Operation Instructions.
- Where unvented heaters are used, gravity or mechanical means shall be provided to supply and exhaust at least 4 CFM per 1,000 Btu/hr input of installed heaters.
- Never use the heater as a support for a ladder or other access equipment. Do not hang anything from the heater.
- Supply all installation materials necessary that are not included with the heater.
- Check the nameplate to make sure that the burner is correct for the gas type in the building and the installation altitude.

## 3.0) GENERAL INFORMATION

This heater is a self-contained infrared radiant tube heater for use in locations where flammable gases or vapors are not generally present (as defined by OSHA acceptable limits) and is intended for the heating of **nonresidential** spaces.

**For indoor installation only. Not for use in residential dwellings.**

### **INSTALLATION REQUIREMENTS**

The installation must conform to local building codes or in the absence of local codes, with the National Fuel Gas Code ANSI Z223.1/NFPA54 or the Natural Gas and Propane Installation Code CSA B149.1. Heaters shall be installed by a licensed contractor or licensed installer. Clearances to combustibles as outlined in this manual should always be observed. In areas used for storage of combustible materials where they may be stacked below the heater, NFPA54 requires that the installer must post signs that will "specify the maximum permissible stacking height to maintain the required clearances from the heater to combustibles."

Every heater shall be located with respect to building construction and other equipment so as to permit access to the heater. Each installer shall use quality installation practices when locating the heater and must give consideration to clearances to combustible materials, vehicles parked below, lights, overhead doors, storage areas with stacked materials, sprinkler heads, gas and electrical lines and any other possible obstructions or hazards. Consideration also must be given to service accessibility.

The heater, when installed in aircraft hangars and public garages, must be installed in accordance with ANSI/NFPA 409-latest edition (Standard for Aircraft Hangars), ANSI/NFPA 88a-latest edition (Standard for Parking Structures), and ANSI/NFPA 88b-latest edition (Standard for Repair Garages) with the following clearances:

- a. At least 10 feet above the upper surfaces of wings or engine enclosures of the highest aircraft that may be housed in the hangar and at least 8 feet above the floor in shops, offices, and other sections of hangars communicating with aircraft storage or service areas.
- b. At least 8 feet above the floor in public garages. **▲WARNING:** Minimum clearances marked on the heater must be maintained from vehicles parked below the heater.

**(FOR CANADA ONLY)**


- a. Installation of this appliance is to be in accordance with latest edition of CSA B149.1 (Natural Gas and Propane Installation Code).
- b. For installation in public garages or aircraft hangars, the minimum clearances from the bottom of the infrared heater to the upper surface of the highest aircraft or vehicle shall be 50 percent greater than the certified minimum clearance, but the clearance shall not be less than 8 feet.

Although these heaters may be used in many applications other than space heating (e.g., process heating), SunStar will not recognize the warranty for any use other than space heating.

This heater is for Indoor Installation and Covered Patio Installation only and can be used in either Vented or Unvented mode. The term Unvented actually means Indirect Vented. While the products of combustion are expelled into the building, national codes require ventilation in the building to dilute these products of combustion. This ventilation may be provided by gravity or mechanical means.

**This heater is not an explosion proof heater.** Where the possibility of exposure to volatile and low flash point materials exists, it could result in property damage or death. This heater must not be installed in a spray booth where the heater can operate during the spraying process. Consult your local fire marshal or insurance company.


**SIS Series Only:** Since straight tube heaters are always hotter at the control end than at the flue terminal end, always observe the minimum recommended mounting heights shown on the specification sheets in Section 5.0 of this manual. Use U-tube configuration instead of straight tubes for spot or area heating (e.g., where a single heater is utilized for space heating).




**High Altitude:**

Appliances are supplied as standard for altitudes of 0 to 2,000 feet (0-610 m). High-altitude ratings are obtained by a change in the orifice size. When ordered for high altitude installations, burners are supplied by the factory ready for high altitude installation. Check the nameplate for altitude before proceeding with the installation. In Canada the adjustment for altitude is made in accordance with Standard CGA 2.17, Gas-Fired Appliances for Use at High Altitudes.

## 4.0) MINIMUM CLEARANCES TO COMBUSTIBLES

| ⚠ WARNING                                                                         |                                                                                   |                                                                                                                                                                                                                                          |
|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|  |  | <p style="text-align: center;"><b>FIRE AND EXPLOSION HAZARD</b></p> <p>Combustible material must be located outside the clearance dimensions listed.</p> <p>Failure to do so may result in death, serious injury or property damage.</p> |

Minimum clearances to combustibles shall be measured from the outer surfaces as shown in the following diagram:



| MINIMUM CLEARANCES TO COMBUSTIBLES |                      |          |         |      |                      |          |
|------------------------------------|----------------------|----------|---------|------|----------------------|----------|
| Model No.                          | Mounted Horizontally |          |         |      | Angle Mounted at 45° |          |
|                                    | Sides                | Ceiling* | Below   | Ends | 45° Front            | 45° Rear |
| SIS/SIU 50                         | 27"                  | 6"       | 40"     | 30"  | 48"                  | 12"      |
| SIS/SIU 75                         | 27"                  | 6"       | 60"     | 30"  | 48"                  | 12"      |
| SIS/SIU 100                        | 66"                  | 6"       | 88" **  | 40"  | 66"                  | 20"      |
| SIS/SIU 125                        | 66"                  | 6"       | 101" ** | 40"  | 66"                  | 20"      |
| SIS/SIU 150, 175                   | 84"                  | 6"       | 106" ** | 48"  | 84"                  | 24"      |

\* When used indirect vented, minimum clearance for CEILING must be: 12" for SIS/SIU 50-75 and 18" for SIS/SIU 100-175. If optional corner and U-bend reflectors are not used, the clearance must be 18".

\*\* Maximum clearance below reduces to 72" once you are 20 ft. downstream from the control box.

**▲ WARNING:** Certain materials or objects, when stored under the heater, will be subjected to radiant heat and could be seriously damaged. Observe the Minimum Clearances to Combustibles listed in the manual and on the heater at all times.

### NOTE:

1. The clearances specified above must be maintained to combustibles and other materials that may be damaged by temperatures 90°F above ambient temperature. Clearances to combustibles are posted on the control box. In areas used for storage of combustible materials where they may be stacked below the heater, NFPA54 requires that the installer must post signs that will "specify the maximum permissible stacking height to maintain the required clearances from the heater to combustibles." SunStar recommends posting these signs adjacent to the heater thermostat or other suitable location that will provide enhanced visibility.

2. The stated clearance to combustibles represents a surface temperature of 90 °F (32 °C) above room temperature. Building materials with a low heat tolerance (such as plastics, vinyl siding, canvas, tri-ply, etc.) may be subject to degradation at lower temperatures. It is the installer's responsibility to assure that adjacent materials are protected from degradation.

## 5.0) SPECIFICATIONS

| Model No.   | Btu/hr Input | Flue Restrictor Plate I.D. & Part # |           | Orifice Size |         |             |         | Minimum * Mounting Height |             |
|-------------|--------------|-------------------------------------|-----------|--------------|---------|-------------|---------|---------------------------|-------------|
|             |              |                                     |           | Natural Gas  |         | Propane Gas |         | @ Horizontal              | @ 45° Angle |
| SIS/SIU 50  | 50,000       | 1-1/8"                              | #42741030 | 3.3mm        | (0.130) | #46         | (0.081) | 11 ft.                    | 10 ft.      |
| SIS/SIU 75  | 75,000       | 1-7/16"                             | #42741010 | #20          | (0.161) | #39         | (0.099) | 13 ft.                    | 12 ft.      |
| SIS/SIU 100 | 100,000      | 1-5/8"                              | #42741060 | #14          | (0.182) | #33         | (0.113) | 13 ft.                    | 12 ft.      |
| SIS/SIU 125 | 125,000      | 1-7/8"                              | #42741080 | #5           | (0.206) | #30         | (0.129) | 14 ft.                    | 13 ft.      |
| SIS/SIU 150 | 150,000      | 2-1/32"                             | #42741090 | 5.7mm        | (0.224) | #28         | (0.140) | 15 ft.                    | 14 ft.      |
| SIS/SIU 175 | 175,000      | 2-1/4"                              | #42741100 | "C"          | (0.242) | 3.8mm       | (0.150) | 15 ft.                    | 14 ft.      |

\* MOUNT HEATERS AS HIGH AS POSSIBLE. Minimums are shown as a guideline for human comfort and uniform energy distribution for complete building heating applications. Consult your SunStar representative for the particulars of your installation requirements.

| Type Gas           | Gas Pipe Connection <sup>1</sup> | Tube Diameter | Flue Connection <sup>2</sup> | Fresh Air Connection | Electrical Supply       | Current Rating |
|--------------------|----------------------------------|---------------|------------------------------|----------------------|-------------------------|----------------|
| Natural or Propane | 1/2" MPT (Male)                  | 4"            | 4" Round                     | 6" Round             | 120 Volt, 60Hz, 1 Phase | 2.6 Amp        |

| Fuse Rating:                          | Ignition System (direct spark): |
|---------------------------------------|---------------------------------|
| In-line: 2 Amp 250V (for 24V Circuit) | 30 second pre-purge period      |

## 6.0) PACKING LIST

### A. SIS/SIU Control/Draft Inducer Package

| Part Description                                                           | QTY |
|----------------------------------------------------------------------------|-----|
| Control Box Assembly .....                                                 | 1   |
| Draft Inducer & Junction Box Assembly .....                                | 1   |
| Flue Restrictor Plate (See Section 5.0) for plate I.D. and part no.) ..... | 1   |
| 4" Starting Collar (#40504020) .....                                       | 1   |
| Control Fastener Kit (#42907110) .....                                     | 1   |
| Containing: #8-32 Screws & Nuts (#02166010 & #02127030) .....              | 2   |
| 1/4 - 20 Locknuts (#02167010) .....                                        | 6   |
| Tube Flange Gasket (#42921000) .....                                       | 2   |
| Draft Inducer Flange (#44015251) .....                                     | 1   |
| Installation & Operation Instructions (#43343310) .....                    | 1   |
| Gas connector, 5/8" OD x 36" (#30302360) .....                             | 1   |

### CONTROL/DRAFT INDUCER PACKAGE NUMBERS

| NATURAL GAS        |           | PROPANE GAS        |           |
|--------------------|-----------|--------------------|-----------|
| MODEL NO.          | PART NO.  | MODEL NO.          | PART NO.  |
| SIS/U 50-N5 .....  | #43502030 | SIS/U 50-L5 .....  | #43502040 |
| SIS/U 75-N5 .....  | #43502070 | SIS/U 75-L5 .....  | #43502080 |
| SIS/U 100-N5 ..... | #43503050 | SIS/U 100-L5 ..... | #43502060 |
| SIS/U 125-N5 ..... | #43503110 | SIS/U 125-L5 ..... | #43503120 |
| SIS/U 150-N5 ..... | #43503170 | SIS/U 150-L5 ..... | #43503180 |
| SIS/U 175-N5 ..... | #43503210 | SIS/U 175-L5 ..... | #43503220 |

**B. SIS Body Package Descriptions***(Package Part Number is indicated on the outside of each corresponding carton.)*

| System Lengths                                          |                                              | 15 Ft.<br>System                | 20 Ft.<br>System                | 30 Ft.<br>System                | 40 Ft.<br>System                | 50 Ft.<br>System                |
|---------------------------------------------------------|----------------------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|
| <b>SIS 50-175 Body Packages – Aluminized/Hot Rolled</b> |                                              | <b>15 Ft. Pkg.<br/>44134000</b> | <b>20 Ft. Pkg.<br/>44135000</b> | <b>30 Ft. Pkg.<br/>44136000</b> | <b>40 Ft. Pkg.<br/>44137000</b> | <b>50 Ft. Pkg.<br/>44138000</b> |
| Part #                                                  | Each Body Package Includes:                  | Qty.                            | Qty.                            | Qty.                            | Qty.                            | Qty.                            |
| 42912080                                                | 10 Ft. Tube with 24 Hole Flange (Aluminized) | 1                               | 1                               | 1                               | 1                               | 1                               |
| 41932101                                                | 10 Ft. Tube less Flanges (Hot Rolled)        | -                               | 1                               | 2                               | 3                               | 4                               |
| 41932051                                                | 5 Ft. Tube less Flanges (Hot Rolled)         | 1                               | -                               | -                               | -                               | -                               |
| 43319100                                                | Reflector, 9' 11½"                           | 1                               | 2                               | 3                               | 4                               | 5                               |
| 43319050                                                | Reflector, 4' 11½"                           | 1                               | -                               | -                               | -                               | -                               |
| 30462980                                                | Tube Coupling                                | 1                               | 1                               | 2                               | 3                               | 4                               |
| 43318000                                                | Tube Hanger/Support Bracket, 13"             | 2                               | 2                               | 3                               | 4                               | 5                               |
| 43980010                                                | Wire Hanger                                  | 2                               | 2                               | 3                               | 4                               | 5                               |

|                                                      |                               |                 |                 |                 |                 |                 |
|------------------------------------------------------|-------------------------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| <b>Body Fastener Kit (included in body packages)</b> |                               | <b>42907190</b> | <b>42907190</b> | <b>42907200</b> | <b>42907210</b> | <b>42907220</b> |
| 42873000                                             | U-Bolt                        | 2               | 2               | 3               | 4               | 5               |
| 02127110                                             | Hex Nut, 5/16-18              | 5               | 5               | 6               | 8               | 10              |
| 02189020                                             | HWHSM Screw, #10-16 x ½" TEKS | 8               | 8               | 10              | 14              | 18              |

**C. SIU Body Package Descriptions***(Package Part Number is indicated on the outside of each corresponding carton.)*

| System Lengths                                          |                                              | 20 Ft.<br>System                | 30 Ft.<br>System                | 40 Ft.<br>System                | 50 Ft.<br>System                |
|---------------------------------------------------------|----------------------------------------------|---------------------------------|---------------------------------|---------------------------------|---------------------------------|
| <b>SIU 50-175 Body Packages – Aluminized/Hot Rolled</b> |                                              | <b>20 Ft. Pkg.<br/>44135000</b> | <b>30 Ft. Pkg.<br/>44136010</b> | <b>40 Ft. Pkg.<br/>44137000</b> | <b>50 Ft. Pkg.<br/>44138010</b> |
| Part #                                                  | Each Body Package Includes:                  | Qty.                            | Qty.                            | Qty.                            | Qty.                            |
| 42912080                                                | 10 Ft. Tube with 24 Hole Flange (Aluminized) | 1                               | 1                               | 1                               | 1                               |
| 41932101                                                | 10 Ft. Tube less Flanges (Hot Rolled)        | 1                               | 1                               | 3                               | 3                               |
| 41932051                                                | 5 Ft. Tube less Flanges (Hot Rolled)         | -                               | 2                               | -                               | 2                               |
| 43319100                                                | Reflector, 9' 11½"                           | 2                               | 2                               | 4                               | 4                               |
| 43319050                                                | Reflector, 4' 11½"                           | -                               | 2                               | -                               | 2                               |
| 30462980                                                | Tube Coupling                                | 1                               | 3                               | 3                               | 5                               |
| 43318000                                                | Tube Hanger/Support Bracket, 13"             | 2                               | 4                               | 4                               | 6                               |
| 43980010                                                | Wire Hanger                                  | 2                               | 4                               | 4                               | 6                               |

|                                                      |                               |                 |                 |                 |                 |
|------------------------------------------------------|-------------------------------|-----------------|-----------------|-----------------|-----------------|
| <b>Body Fastener Kit (included in body packages)</b> |                               | <b>42907190</b> | <b>42907200</b> | <b>42907210</b> | <b>42907220</b> |
| 42873000                                             | U-Bolt                        | 2               | 4               | 4               | 5               |
| 02127110                                             | Hex Nut, 5/16-18              | 5               | 8               | 8               | 10              |
| 02189020                                             | HWHSM Screw, #10-16 x ½" TEKS | 8               | 14              | 14              | 18              |

|                       |                                 |                 |                 |                 |                 |
|-----------------------|---------------------------------|-----------------|-----------------|-----------------|-----------------|
| <b>U-Bend package</b> |                                 | <b>43208020</b> | <b>43208020</b> | <b>43208020</b> | <b>43208020</b> |
| 42913020              | U-Bend                          | 1               | 1               | 1               | 1               |
| 43318500              | 31" Tube Support/Hanger Bracket | 1               | 1               | 1               | 1               |
| 30462980              | Tube Coupling                   | 1               | 1               | 1               | 1               |
| 02189020              | HWHSM Screw, #10-16 x ½" TEKS   | 2               | 2               | 2               | 2               |

**D. "TOUGH GUY" SIS Body Package Descriptions***(Package Part Number is indicated on the outside of each corresponding carton.)*

| System Lengths                        |                                              | 15 Ft.<br>System        | 20 Ft.<br>System        | 30 Ft.<br>System        | 40 Ft.<br>System        | 50 Ft.<br>System        |
|---------------------------------------|----------------------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|-------------------------|
| SIS 50-175 Body Packages – Aluminized |                                              | 15 Ft. Pkg.<br>44134010 | 20 Ft. Pkg.<br>44135020 | 30 Ft. Pkg.<br>44136020 | 40 Ft. Pkg.<br>44137040 | 50 Ft. Pkg.<br>44138060 |
| Part #                                | Each Body Package Includes:                  | Qty.                    | Qty.                    | Qty.                    | Qty.                    | Qty.                    |
| 42912080                              | 10 Ft. Tube with 24 Hole Flange (Aluminized) | 1                       | 1                       | 1                       | 1                       | 1                       |
| 41932100                              | 10 Ft. Tube less Flanges (Aluminized)        | -                       | 1                       | 2                       | 3                       | 4                       |
| 41932050                              | 5 Ft. Tube less Flanges (Aluminized)         | 1                       | -                       | -                       | -                       | -                       |
| 43319100                              | Reflector, 9' 11½"                           | 1                       | 2                       | 3                       | 4                       | 5                       |
| 43319050                              | Reflector, 4' 11½"                           | 1                       | -                       | -                       | -                       | -                       |
| 30462980                              | Tube Coupling                                | 1                       | 1                       | 2                       | 3                       | 4                       |
| 43318000                              | Tube Hanger/Support Bracket, 13"             | 2                       | 2                       | 3                       | 4                       | 5                       |
| 43980010                              | Wire Hanger                                  | 2                       | 2                       | 3                       | 4                       | 5                       |

| Body Fastener Kit (included in body packages) |                               | 42907190 | 42907190 | 42907200 | 42907210 | 42907220 |
|-----------------------------------------------|-------------------------------|----------|----------|----------|----------|----------|
| 42873000                                      | U-Bolt                        | 2        | 2        | 3        | 4        | 5        |
| 02127110                                      | Hex Nut, 5/16-18              | 5        | 5        | 6        | 8        | 10       |
| 02189020                                      | HWHSM Screw, #10-16 x ½" TEKS | 8        | 8        | 10       | 14       | 18       |

**E. "TOUGH GUY" SIU Body Package Descriptions***(Package Part Number is indicated on the outside of each corresponding carton.)*

| System Lengths                        |                                              | 20 Ft.<br>System        | 30 Ft.<br>System        | 40 Ft.<br>System        | 50 Ft.<br>System        |
|---------------------------------------|----------------------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|
| SIU 50-175 Body Packages – Aluminized |                                              | 20 Ft. Pkg.<br>44135020 | 30 Ft. Pkg.<br>44136030 | 40 Ft. Pkg.<br>44137040 | 50 Ft. Pkg.<br>44138070 |
| Part #                                | Each Body Package Includes:                  | Qty.                    | Qty.                    | Qty.                    | Qty.                    |
| 42912080                              | 10 Ft. Tube with 24 Hole Flange (Aluminized) | 1                       | 1                       | 1                       | 1                       |
| 41932100                              | 10 Ft. Tube less Flanges (Aluminized)        | 1                       | 1                       | 3                       | 3                       |
| 41932050                              | 5 Ft. Tube less Flanges (Aluminized)         | -                       | 2                       | -                       | 2                       |
| 43319100                              | Reflector, 9' 11½"                           | 2                       | 2                       | 4                       | 4                       |
| 43319050                              | Reflector, 4' 11½"                           | -                       | 2                       | -                       | 2                       |
| 30462980                              | Tube Coupling                                | 1                       | 3                       | 3                       | 5                       |
| 43318000                              | Tube Hanger/Support Bracket, 13"             | 2                       | 4                       | 4                       | 6                       |
| 43980010                              | Wire Hanger                                  | 2                       | 4                       | 4                       | 6                       |

| Body Fastener Kit (included in body packages) |                               | 42907190 | 42907200 | 42907210 | 42907220 |
|-----------------------------------------------|-------------------------------|----------|----------|----------|----------|
| 42873000                                      | U-Bolt                        | 2        | 4        | 4        | 5        |
| 02127110                                      | Hex Nut, 5/16-18              | 5        | 8        | 8        | 10       |
| 02189020                                      | HWHSM Screw, #10-16 x ½" TEKS | 8        | 14       | 14       | 18       |

| U-Bend package |                                 | 43208020 | 43208020 | 43208020 | 43208020 |
|----------------|---------------------------------|----------|----------|----------|----------|
| 42913020       | U-Bend                          | 1        | 1        | 1        | 1        |
| 43318500       | 31" Tube Support/Hanger Bracket | 1        | 1        | 1        | 1        |
| 30462980       | Tube Coupling                   | 1        | 1        | 1        | 1        |
| 02189020       | HWHSM Screw, #10-16 x ½" TEKS   | 2        | 2        | 2        | 2        |




## 6.1) ACCESSORY PACKAGES

### A. End Reflector Accessory Package, Part #43341010 (1 pkg. per SIS Series or 2 pkgs. per SIU Series)

**Contains:**


End Reflector, #43320000.....QTY-2  
Speed Clips, #02266010.....QTY-4



### B. Elbow Accessory Package, Part #43208010 (Option for SIS Series Only)

**Contains:**


Elbow, #43175000.....QTY-1  
#10-16 x 1/2 Self-Drilling Screws, #02189020.....QTY-2  
Tube Coupling, #30462980.....QTY-1



### C. Corner Reflector Accessory Package, Part #43342000 (Option for SIS Series Only)

**Contains:**


Corner Reflector Assembly, #43345000.....QTY-1  
Speed Clips, #02266010.....QTY-4



### D. U-Bend Package, Part #43208020 (Option for SIU Series Only)

**Contains:**


U-Bend, #42913020.....QTY-1  
#10-16 x 1/2 Self-Drilling Screws, #02189020.....QTY-2  
Tube Coupling, #30462980.....QTY-1  
31" Tube Support/Hanger Bracket, #43318500.....QTY-1




### E. U-Bend Reflector Package, Part #43488000 (Option for SIU Series Only)

**Contains:**

U-Bend Reflector, #43490000.....QTY-1  
U-Bend End Reflector, #43490050.....QTY-1  
Speed Clips, #02266010.....QTY-11  
#10-16 x 1/2 Self-Drilling Screws, #02189020.....QTY-4  
Installation Form, #43489000.....QTY-1



**F. 31" Hanger/Tube Support, Part #43318500**  
*(Option for Angle Mounting of SIU Series)*




**G. Exhaust Hood Package, Part #42924000**


**Contains:**

Exhaust Hood Assembly, #42925540.....QTY-1

#8-18 x 1/2 Self-Drilling Screws, #02189030.....QTY-2



## 7.0) TYPICAL LAYOUTS




### NOTES:

1. In all configurations, the control unit must be connected directly to the 24-hole flange of the 10 ft. aluminized steel start/end body section.
2. Joining of two 90° elbows directly together to form a “Z” shape **IS NOT** permitted.
3. Any configuration of components not shown in the illustrations may be used except as noted in 1 and 2 above.



| MODEL   | EMITTER LENGTH |        | MODEL   | EMITTER LENGTH |        |
|---------|----------------|--------|---------|----------------|--------|
|         | Min.           | Max.   |         | Min.           | Max.   |
| SIS 50  | 15 Ft.         | 30 Ft. | SIU 50  | 20 Ft.         | 30 Ft. |
| SIS 75  | 20 Ft.         | 30 Ft. | SIU 75  | 20 Ft.         | 30 Ft. |
| SIS 100 | 30 Ft.         | 40 Ft. | SIU 100 | 30 Ft.         | 40 Ft. |
| SIS 125 | 30 Ft.         | 50 Ft. | SIU 125 | 30 Ft.         | 50 Ft. |
| SIS 150 | 40 Ft.         | 50 Ft. | SIU 150 | 40 Ft.         | 50 Ft. |
| SIS 175 | 40 Ft.         | 50 Ft. | SIU 175 | 40 Ft.         | 50 Ft. |

**Typical Dimensions Up to 50 Ft. Shown.**




## 8.1) DIMENSIONS – SIU SERIES



Typical Dimensions Up to 50 Ft. Shown.



## 8.2) HEATER ASSEMBLY / JOINING OF TUBE SECTIONS



# Typical Assembly Overview (SIU 40FT Shown)



6 hanging points to be used for suspension. There must be two hanging points on the first tube and one on each of the other tubes

## 9.0) TYPICAL SUSPENSION METHODS


| ⚠ WARNING                                                                         |                                                                                                                                                                                                                                                                                                                                                                                                                                  |
|-----------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|  | <p style="text-align: center;"><b>SUSPENSION HAZARD</b></p> <p>Burner must be secured to the mounting flange with nuts.</p> <p>All materials used to suspend the heater must have a minimum working load of 115 lbs.</p> <p>All "S" Hooks must be crimped closed.</p> <p>Never use the heater to support a ladder or other access equipment.</p> <p>Failure to do so may result in death, serious injury or property damage.</p> |

Various means of suspending the heater can be used. See the following drawings for typical examples.

1. Use only noncombustible materials for suspending hangers and brackets.
2. A minimum No. 2 chain with a working load limit of 115 lbs. is required.
3. Turnbuckles can be used with chains to allow leveling of the heater. All "S" hooks and eye bolts must be manually crimped closed by the installer.
4. When using rigid means for heater suspension (rod, flat bar, etc.) provide sufficient lengths or swing joints to compensate for expansion. See Figures b and c.
5. Heaters subject to vibration must be provided with vibration isolating hangers.
6. Heaters must not be supported by gas or electric supply lines and must be suspended from a permanent structure with adequate load capacity.

SunStar recommends that the body sections be suspended using chains with turnbuckles. This will allow slight adjustments after assembly and heater expansion/ contraction during operation.

If a "trapeze" method is used for tube support/hanger brackets (shown below), the minimum chain length for the two connecting chains is 36" to minimize any vibration that might be generated by the draft inducer assembly. If these chains must be less than 36", then do not use the trapeze method and, instead, use individual chains on each tube support/hanger bracket.





## 10.0) ASSEMBLY OF TUBE SECTIONS

### CAUTION



#### CUT HAZARD

Sheet metal parts, particularly reflectors and vent have sharp edges. Always use gloves when handling.


Failure to do so may result in death, serious injury or property damage.

During field assembly of the heater body sections, the recommended procedure is as follows:


1. Before hanging heater sections, first determine the actual layout of the system (see Sections 7.0) & 8.0) for details). Consideration must also be taken for flue pipe, fresh air ducting, gas piping, clearances to combustibles, etc. before hanging heater. Typical suspension methods are shown in Section 9.0).
2. Hang each tube section individually. **DO NOT** attach the heater tube sections together on the ground and attempt to hang the entire system.
3. The first 10' tube section must be aluminized steel (with 24-hole flange) as the primary heat exchanger and the control box connected directly to these tube sections. **Failure to attach the control box to the flange end as indicated above will void the manufacturer's warranty.**
4. Place a tube support/hanger bracket on the end of the heat exchanger tube having the mounting flange. Align the tube such that the welded seam is facing down toward the ground. **Failure to assemble the tube with the seam facing down will VOID the manufacturer's warranty.**
5. Space the tube support/hanger bracket 6 inches from center of its slotted holes to the front face of the mounting flange. Secure the tube to the support/hanger bracket using a "U" Bolt clamp and two (2) 5/16-18 nuts provided. For U-tube configuration, see typical assembly overview illustration in Section 8.2)
6. Suspend the chain to attach the wire hanger and the tube support bracket. Insert the tube into the wire hanger and then raise the tube support bracket end up to the suspension chain, use "S" hooks to attach the wire hanger and tube support bracket to the chain.

### CAUTION

**Failure to assemble the tube with the seam facing down will VOID the manufacturer's warranty.**



## 10.1) ASSEMBLY OF EXTENSION SECTIONS




See typical assembly overview (Section 8.0) for typical complete assembly. Assemble additional extension sections as required for all systems. (See Sections 7.0) and 8.0) for typical layout details.)

Join the tube sections together and secure with tube couplings as described below:


### **! WARNING**

The following coupling tightening instructions **MUST** be followed properly to ensure the integrity of the tube connections. Two #10 self-drilling screws **MUST** be installed at every coupling as shown in the instructions below. Failure to do so may result in serious injury or property damage.


1. Place the compression coupling over the end of the tube.
2. Use the small hole at the centerline of the coupling to check that the coupling is inserted correctly.
3. Partially tighten the bolt nearest the end of the tube (approximately half closed).



4. Slide the next tube into the coupling.
5. Make sure both tube ends are butted together.
6. Finish tightening both bolts to 40-60 ft.lbs. torque to ensure a complete seal.
7. Use the two Self-drilling screws through the pre-punched holes to secure the tubes in the coupling.



8. Check to ensure that the hardware is completely closed and the band is seated on the reaction block and interference pins as illustrated above.
9. Once all the heater body sections are attached, make sure that the heater system is level. If it is not, slight adjustments can be made using the turnbuckles. (See Section 9.0)




## CAUTION

**Important: NEVER reuse a coupling. Always install a new coupling only and torque as per instructions above and the diagrams above.**

## 10.2) ADDING REFLECTORS


1. Slide the reflectors on the tube support/hanger brackets and through the wire hangers.
2. The tube at the coupling joints must be covered. Slide the reflectors together and provide an overlap of two (2") inches for the first reflector overlap after the control unit. All remaining reflector overlaps will be approximately one (1") inch. This will allow for the natural expansion and contraction of the heater when in operation. **Note: The heaters can expand and contract up to 1-3/4 inch.** See Detail "B" for the correct installation of reflector overlaps.

- Secure the reflectors as shown in Detail "A" using #10 x 1/2" self-drilling sheet metal screws at each tube support/hanger bracket.




### 10.3) ADDING OPTIONAL 90° ELBOW (SIS ONLY)

- The optional 90° elbow must be located a minimum of 10 ft. after the control box.
- Hang the body sections in a 90° ("L") shaped pattern. Allow spacing for the elbow. The distance from one end of the elbow to the centerline of the opposite leg is 13" as shown.
- Join the tube ends of the body sections and the elbow together and secure with tube couplings as described in Section 10.1).




## 10.4) ADDING OPTIONAL CORNER REFLECTOR (SIS ONLY)

1. Place the corner reflector over the reflectors of both body sections.
2. Secure by sliding speed clips on the reflector edges. One speed clip is required for each side of reflector.
3. The corner reflector can be used only when the long axis of the heater is level and mounted in a horizontal position.




## 10.5) ADDING 180° U-BEND (SIU ONLY)

1. Hang body sections parallel with each other. The centerline distance from tube at each body section should be 18" as shown.
2. Join tube ends of body sections and the U-Bend together and secure with tube couplings as described in Section 10.1).




## 10.6) ADDING OPTIONAL U-BEND REFLECTOR (SIU ONLY)

1. Place the **U-Bend Reflector** over the reflectors of each body section with the end resting next to the tube wire hangers as shown.
2. Slide the speed clips on the reflector edges towards the end of the body section reflectors. Two speed clips are required for each side of the **U-Bend Reflector**. Make sure that the speed clips fit tightly over both the **U-Bend Reflector** and the reflector on each body section. Use two self-drilling screws to permanently secure both sides to the reflectors.
3. Place the **End Reflector** flush with the **U-Bend Reflector** as shown. **Note:** Clearance between end of the **U-Bend Reflector** and the **U-Bend** must be a minimum of **1"**. Secure by sliding speed clips onto the end reflector edges. Evenly space the speed clips on the sides (two each side) and top (three each) of the reflectors to provide a snug fit.




## 11.0) ATTACHING CONTROL BOX ASSEMBLY

1. Attach the control box and gasket to end of tube flange and secure with 1/4-20 locknuts. **NOTE: The control box must be mounted to a 10 ft. aluminized steel body section regardless of configuration used. Failure to attach the control box to the flange end as indicated above will void the manufacturer's warranty.**
2. A 3/8" connector is located on the left side of the control cabinet to provide strain relief for field wiring to the draft inducer junction box (refer to Section 16.0) on Electrical Connections and Connection Wiring Diagram for wiring between the control box and the draft inducer.)
3. Assemble the end reflector (optional on SIS/SIU series) flush with the end of the main body reflector. Secure by sliding speed clips onto the reflector edges. Evenly space the speed clips on the sides (one each side) and top (two required) of the reflectors to provide a snug fit. Leave a 3" space between the end reflector and the control box assembly.
4. The control box must be mounted with the perforated fresh air plate on top, facing the ceiling.



5. The heater can be mounted **horizontally** or at an angle of up to **45 degrees** maximum from horizontal.


When angle mounting, the **control box** must be positioned **upright** as shown below. **Failure to install the control box in an UPRIGHT position will VOID the manufacturer's warranty.** For additional instructions see Section 13.0) for multiple hanging and draft inducer positions.



6. **Control box** can be installed in lower side when angle mounting. Please ensure that there is adequate clearance to open the **control box** access panel for servicing the heater.

## 12.0) ATTACHING DRAFT INDUCER ASSEMBLY

1. Slide the draft inducer flange over the end of tube. Rotate the flange until the tightening brackets are in the upright position. Secure the flange by tightening the 1/4-20 screw located on the tightening brackets.
2. Attach the draft inducer assembly and gasket to end of the draft inducer flange and secure with 1/4-20 locknuts. A flue restrictor plate is attached to the draft inducer weld studs. **DO NOT DISCARD RESTRICTOR PLATE** and make sure this remains in place while the draft inducer is being attached to the heater body. **NOTE:** The draft inducer can be mounted in a vertical, a 45°, or a horizontal position. Refer to Section 13.0).
3. The 3/8" connector used to hold the SJO cable will remain to provide strain relief for field wiring of the control box and the draft inducer (refer to the Electrical Connections and Connection Wiring Diagram for wiring between the control box and the draft inducer in Section 16.0).
4. If the heater is to be VENTED to the outside of the building, place the starting collar on the outlet of the draft inducer and secure with the #8-32 screws and nuts. Place the flue pipe directly onto the starting collar, secure with the #8 sheet metal screws, and terminate with an approved vent cap.
5. If the heater is for UNVENTED use, place the exhaust hood (supplied as an accessory) directly onto the outlet of the draft inducer (starting collar is not necessary for unvented use). Secure with the #8 sheet metal screws. **The exhaust hood must be mounted only in an upright position and directed toward the reflector body.**
6. Assemble the end reflector (optional on SIS/SIU series) flush with the end of the main body reflector. Secure by sliding speed clips onto the reflector edges. Evenly space the speed clips on the sides (one each side) and top (two required) of the reflectors to provide a snug fit. Leave a 3" space between the end reflector and the draft inducer assembly.






### 13.0) MULTIPLE HANGING & DRAFT INDUCER POSITIONS


The heater can be mounted horizontally or at an angle of 45° maximum from horizontal. Make sure the long axis of heater is level.

Multiple draft inducer positions can also be used as shown in the diagrams. This allows for the desired configuration of flue venting. Regardless of the position chosen, the junction box must remain horizontal as shown. This may be achieved as follows:

1. Remove the three (3) 1/4-20 locknuts securing the motor and blower wheel assembly.
2. Pull the motor and blower wheel assembly with the motor plate slightly from the end of the housing studs. Use care not to damage the motor leads.
3. Rotate the junction box assembly to the upright position using the multi-hole mounting bracket.
4. Replace the motor and blower assembly. Tighten the locknuts.
5. Horizontal and 45° draft inducer positions can allow the plastic vacuum air tube to sag. The air tube should be shortened to prevent a downward sag that could allow condensation build-up in the tube.



## 14.0) GAS CONNECTIONS AND REGULATIONS


| ⚠ WARNING                                                                         |                                                                                   |                                                                                                                                                                                                                                                                                                                                                               |
|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|  |  | <p><b>FIRE AND EXPLOSION HAZARD</b></p> <p>Tighten flexible gas hose and components securely.</p> <p>Flexible metal gas hoses must be installed without any twists or kinks in them. The hose will move during operation of the heater and it can crack if it is twisted.</p> <p>Failure to do so may result in death, serious injury or property damage.</p> |

### IMPORTANT BEFORE CONNECTING THE GAS TO THE HEATER


1. Connect to the supply tank or manifold in accordance with the latest edition of National Fuel Gas Code (ANSI Z223.1), and local building codes. Authorities having jurisdiction should be consulted before the installation is made. (In Canada, refer to the latest edition of CSA B149.1, Natural Gas and Propane Installation Code.)
2. Check that the gas fuel on the burner rating plate matches the fuel for the application.
3. Check that the gas supply piping has the capacity for the total gas consumption of the heaters and any other equipment connected to the line.
4. Check that the calculated supply pressure with all gas appliances and heaters operating will not drop below the minimum supply pressure required for these heaters. Check inlet supply pressures on Section 15.0).
5. All gas supply lines must be located in accordance with the required clearances to combustibles from the heater as listed on the clearances label of the heater and Section 4.0) of this manual.
6. Pipe joint compounds must be resistant to the action of liquefied petroleum gases.
7. Tube heaters will expand/contract during operation. Where local codes do not prohibit, a CSA or U.L. approved flexible connector supplied with this heater is required for connections between the rigid piping and the heater. A union should be installed before the control box inlet. An approved shut off valve should be installed within 6 feet of the union.
8. The gas pipe, flexible hose and connections must be self supporting. The gas pipe work must not bear any of the weight of the heater or any other suspended assembly.
9. This appliance is equipped with a step-opening, combination gas valve. **The maximum supply pressure to the appliance is 14" W.C. or 1/2 P.S.I.** If the line pressure is more than the maximum supply pressure, then a second stage regulator which corresponds to the supply pressure must be used.
10. After all gas connections have been made, make sure the heater and all gas outlets are turned off before the main gas supply is turned on slowly. Turn the gas supply pressure on and check for leaks. To check for leaks, check by one of the methods listed in Appendix D of the National Fuel Gas Code.
11. If a 2nd stage regulator is used, the ball valve down stream in the supply line must be closed when purging the gas lines to prevent gas seeping through it. If initial gas pressure is higher than 14" w.c. the redundant combination gas valve is designed to lock out. Pressure build-up in the supply lines prior to the heater must be released before proper heater operation.

| ⚠ WARNING | DO not use an open flame of any kind to test for leaks. |
|-----------|---------------------------------------------------------|
|-----------|---------------------------------------------------------|

## KEY DIMENSIONS AND COMPONENTS OF THE GAS CONNECTIONS



### INCORRECT POSITIONS



## ! WARNING

**US ONLY:** Connector **MUST** be installed in "C" configuration. Use only the 36" long connector that was furnished with this heater.

**US ONLY:** A gas connector certified for use on a tubular type infrared heater per the standard for Connectors for Gas Appliances, ANSI Z21.24/CSA 6.10 is supplied for installation in US only. The gas connector is 36" long and 1/2" nominal ID, and must be installed as shown above, in one plane, and without sharp bends, kinks or twists.

**CANADA ONLY:** A Type I hose connector should be used that is certified as being in compliance with the Standard for Elastomeric Composite Hose and Hose Couplings for Conducting Propane and Natural Gas (CAN/CGA 8.1) and is of length of 36+/- 6 in (90+/- 15 cm). The gas connector must be installed as shown above, in one plane, and without sharp bends, kinks or twists.


## 15.0) INSTRUCTIONS FOR PRESSURE TEST GAUGE CONNECTION

### SUPPLY PRESSURE

1. The installer will provide a 1/8" N.P.T. tapped plug, accessible for test gauge connection immediately upstream of the gas supply connection to the heater.

### MANIFOLD PRESSURE – COMBINATION GAS VALVE IS FACTORY SET

1. Turn the gas valve to the "OFF" position. Remove the 1/8" plug from the combination gas valve at the **Outlet Pressure Tap** shown below and connect a 1/8" nipple to the tapped hole. Connect the test gauge to the nipple. Turn on the gas supply.



2. With the main burner operating, check the burner manifold pressure using a water column manometer. Gauges that measure pressure in pounds per square inch are not accurate enough to measure or set the manifold pressure. All measurements **MUST BE** made when this heater and all other gas burning equipment that is connected to the gas supply system are operating at maximum capacity.
3. **The combination gas valve is factory set and should not require adjustment.** If full rate adjustment is required, remove the cover screw. Using a small screwdriver, turn the adjustment screw clockwise ⤵ to increase or counterclockwise ⤴ to decrease the gas pressure to the burner. Replace the cover screw. **NOTE: The step opening pressure of this gas valve is not adjustable.**
4. Check the burner at step pressure, observing burner ignition and flame characteristics. The burner should ignite properly and without flashback to the orifice, and should remain lit.


| GAS PRESSURE TABLE |                   |                      |          |
|--------------------|-------------------|----------------------|----------|
| GAS TYPE           | MANIFOLD PRESSURE | SUPPLY PRESSURE      |          |
|                    |                   | Minimum*             | Maximum  |
| Natural Gas        | 3.5" W.C.         | 5" W.C. <sup>1</sup> | 14" W.C. |
| Propane Gas        | 10.0" W.C.        | 11" W.C.             | 14" W.C. |

\* Minimum permissible gas supply pressure for purpose of input adjustment.

<sup>1</sup> 7" W.C. for SIS/U 150-175

## 16.0) ELECTRICAL CONNECTIONS

### ⚠ WARNING




#### ELECTRIC SHOCK HAZARD

Disconnect electrical power and gas supply before servicing.

This appliance must be connected to a properly grounded electrical source.


Failure to do so may result in death or serious injury.

1. All electric wiring shall conform to the latest edition of the National Electrical Code (ANSI/NFPA No. 70), or the code legally authorized in the locality where the installation is made.
2. The unit must be electrically grounded in accordance with the National Electrical Code (ANSI/NFPA No. 70-latest edition). In Canada, refer to current standard C22.1 Canadian Electrical Code Part 1.
3. The wiring providing power to the heater shall be connected to a permanently live electrical circuit, one that is not controlled by a light switch.
4. The power supply to the unit should be protected with a fused disconnect switch or circuit breaker. A service switch, as required by local codes, shall be located in the vicinity of the heater (check local codes for allowable distances) and should be identified as Heater Service Switch. All electrical wiring must be located in accordance with the required Clearances to Combustibles from the heater as listed on the nameplate on the heater.
5. When connecting the **supply circuit** to the heater, wiring material having a minimum size of 14 AWG and a temperature rating of at least 90°C shall be used.



6. **SIS SERIES ONLY:** The installer will provide type SJO wire cable having minimum size of 18 AWG and connect the ends to the draft inducer junction box and the control box. Secure with 3/8" connectors as previously described in the attachment of the control box and draft inducer. Connect wire leads as shown in the Connection Wiring Diagram. The SJO cable should be located and secured to protect it from mechanical damage.


## INTERNAL CONNECTION WIRING DIAGRAM — Direct Spark Ignition



### NOTES:


1. If any of the original wire as supplied with the appliance must be replaced, it must be replaced with wiring material having a temperature rating of at least 105°C. (18 Ga. CSA 600V Type TEW)
2. When connecting the supply circuit to the heater, wiring material having a minimum size of 14 AWG and a temperature rating of at least 90°C shall be used.
3. A replaceable 2-amp fuse (1-1/4" long) is fitted to the terminal block located inside the junction box assembly.

## SCHEMATIC WIRING DIAGRAM — Direct Spark Ignition




## FIELD CONNECTION AND THERMOSTAT WIRING DIAGRAMS


### A. LINE VOLTAGE (120V) THERMOSTAT CONNECTIONS – SINGLE HEATER PER THERMOSTAT



### B. LINE VOLTAGE (120V) THERMOSTAT CONNECTIONS – MULTIPLE HEATERS PER THERMOSTAT



### C. LOW VOLTAGE (24V) THERMOSTAT CONNECTIONS – SINGLE HEATER PER THERMOSTAT




**Order 24V Relay Kit (Part No. 43274030) for Low Voltage (24V) thermostat connection.**

#### NOTES:

1. If any of the original wire as supplied with the appliance must be replaced, it must be replaced with wiring material having a temperature rating of at least 105°C. (18 Ga. CSA 600V Type TEW)
2. When connecting the supply circuit to the heater, wiring material having a minimum size of 14 AWG and a temperature rating of at least 90°C shall be used.
3. A replaceable 2-amp fuse (1-1/4" long) is fitted to the terminal block located inside the junction box assembly.


### D. LOW VOLTAGE (24V) THERMOSTAT CONNECTIONS – MULTIPLE HEATERS PER THERMOSTAT





## 17.0) VENTING

### ⚠ WARNING



#### CARBON MONOXIDE HAZARD

Heaters installed in an unvented mode require a minimum ventilation flow of 4 CFM per 1,000 Btu/hr of total installed capacity.


In buildings with airborne contamination the heater must be installed with fresh air for combustion.

Failure to do so may result in death, serious injury, property damage or illness from Carbon Monoxide poisoning.

- A. BASIC FLUE VENTING** — Venting must comply with the latest edition of the National Fuel Gas Code (ANSI Z223.1-latest edition) or the authority having jurisdiction. Other venting references are in the equipment volume of the ASHRAE Handbook.

#### **SINGLE HEATER VENTING (VERTICAL THROUGH THE ROOF)**

1. When venting the heater to outside of building through a roof, use single-wall metal pipe. This is to be constructed of galvanized sheet metal or other approved noncombustible corrosion-resistant material as allowed by state or local codes.
2. A vent passing through a combustible roof shall extend through an approved clearance roof thimble. Double-wall, Type B vent must be used for the portion of the vent system which passes through the combustible roof. An approved vent cap must be attached to end of the flue.
3. The maximum equivalent length of vent pipe should be carefully observed. A safety switch in the heater is designed to shut the heater off before excessive flue restriction causes bad combustion. Refer to the Vent Sizing Table for vent pipe diameter.
  - Minimum Equivalent Length = 5 ft. of pipe
  - Maximum Equivalent Length = 100 ft. of 4" pipeUse the following correction factors to obtain the equivalent length:
  - Subtract 15 ft. if the run is horizontal. (maximum horizontal length for 4" pipe is 25 ft.)
  - Subtract 10 ft. for an approved vent cap.
  - Subtract 10 ft. for each elbow beyond 15 ft. from the heater.
  - Subtract 15 ft. for each elbow within 15 ft. of the heater.
4. Joints between sections of piping shall be fastened by sheet metal screws or other approved means and should be sealed to prevent leakage of flue gas into building. Aluminum or Teflon tape suitable for 550°F (3M Company tapes 433 or 363) or silicone sealant is recommended.
5. Avoid locating elbows in the first 5' of vent pipe whenever possible. Limit to (2) 90° elbows. When vent pipe is in a horizontal run, it must have 1/4 inch per foot rise.
6. All portions of the vent pipe shall be supported to prevent from sagging (6' spacing is recommended).
7. When the vent pipe passes through areas where the ambient temperature is likely to induce condensation of the flue gases, the vent pipe should be insulated and a condensation drain should be provided.
8. Minimum clearance for single-wall flue pipe to combustible material shall be 6 inches. This may be reduced when the combustible material is protected as specified in the National Fuel Gas Code or the authority having jurisdiction.
9. Single-wall metal pipe shall not originate in any unoccupied attic or concealed space and shall not pass through any attic, inside wall or concealed space, or through any floor. For the installation of a single-wall metal pipe through an exterior combustible wall, refer to latest edition of the National Fuel Gas Code or the authority having jurisdiction.
10. A venting system shall terminate at least 3 ft. above any forced air inlet located within 10 ft.



### **SINGLE HEATER VENTING (HORIZONTAL THROUGH SIDEWALL)**


When venting the heater horizontally through a combustible outside sidewall, the same requirements listed previously for venting **Vertical Through The Roof** apply except as follows:

1. A vent passing through a combustible wall must pass through an approved clearance thimble (Air-Jet #4VT or Ameri-Vent #4EWT or other thimbles) that are listed by a nationally recognized testing agency. Double-wall Type B vent must be used for the portion of the vent system which passes through the combustible sidewall.
2. An approved vent cap (Breidert or equal) must be attached to the end of the vent pipe.
  - 4" vent – 25 ft. maximum with one 90° elbow and vent cap
  - 6" vent – 75 ft. maximum with maximum two 90° elbows and vent cap

If other horizontal vent configurations are required, consult the manufacturer.

**NOTE:** To minimize problems associated with condensation in long horizontal runs, vent pipe can be insulated.

3. When venting through a sidewall, the horizontal vent pipe shall rise not less than 1/4 inch per foot from the start of the vent system to the vent terminal. All portions of the vent pipe shall be supported to prevent sagging. (6' spacing is recommended)
4. A minimum clearance of 6 inches must be maintained between the outside wall and vent cap (18" clearance will provide stability under high wind conditions).
5. The horizontal venting system shall not terminate:
  - Less than 4 ft. (1.2m) below, 4 ft. (1.2m) horizontally from or 1 ft. (30cm) above any door, operable window or gravity air inlet into any building. The bottom of the vent terminal shall be located at least 7 ft. (2.1m) above grade or above snow accumulation level as determined by local codes.
  - Less than 3 ft. (0.9m) from a combustion air inlet.
  - Less than 3 ft. (0.9m) from any other building opening or any gas service regulator.
  - Less than 7 ft. (2.1m) above public walkways.
  - Directly over areas where condensate or vapor could create a nuisance or hazard or be harmful to the operation of gas utility meters, regulators, relief valves, or other equipment. Building materials should be protected from flue gases and condensate.
  - Less than 12" (0.30m) when directly below a combustible overhang.
6. In regions of the country where prevailing winds are consistently higher than 40 mph, it may be necessary to terminate the vent system above the roof level.



Note: Junction Box is not shown.

### **MULTIPLE HEATER VENTING (CONNECTIONS INTO A COMMON VENT OR MANIFOLD)**


Requirements for venting of multiple heaters are the same as described for **SINGLE HEATER VENTING** except as follows:

1. The common vent size and total vent height is normally determined by the number of heaters per common vent, length of horizontal connector runs, and connector rise. Connector lengths should be as short as possible and have a minimum 1/4 inch per foot rise. Without regard to connector rise and total vent height due to many possible venting configurations, the following should be observed:
  - Common vent pipe & vent connector diameter should be no less than that shown in the following Vent Sizing Table.
  - The connector length should be no more than 75% of the vertical portion of vent above the connector.
  - Where possible, use a Y-connector to the common vent.
2. Material for connectors should be constructed of galvanized sheet metal or other approved noncombustible corrosion resistant material as allowed by state or local codes. All common vent pipe should be insulated flue pipe or double-wall, Type B vent.
3. Avoid unnecessary bends. Limit to two (2) 90° elbows.
4. The entire length of vent connector shall be readily accessible for inspection, cleaning and replacement.
5. Groups of heaters with a common vent must be controlled by a common thermostat.


## **⚠ WARNING**

**If any heater connected to a common vent system for multiple heaters is found inoperative, the heater should be disconnected from the vent system and its entrance into the vent system capped.**


### **Multiple Heater Vertical Venting Arrangement**



### Multiple Heater Horizontal Venting Arrangement




### Multiple Heater Venting (Connections into a Manifold)



| VENT SIZING TABLE — Multiple Heater Venting                                           |                   |    |    |    |     |
|---------------------------------------------------------------------------------------|-------------------|----|----|----|-----|
|                                                                                       | Number of Heaters |    |    |    |     |
|                                                                                       | 1                 | 2  | 3  | 4  | 5   |
| SIS/U50                                                                               | 4"                | 4" | 5" | 5" | 6"  |
| SIS/U75                                                                               | 4"                | 5" | 6" | 6" | 7"  |
| SIS/U100                                                                              | 4"                | 6" | 6" | 7" | 8"  |
| SIS/U125                                                                              | 4"                | 6" | 7" | 8" | 9"  |
| SIS/U150-175                                                                          | 4"                | 6" | 8" | 9" | 10" |
| <b>COMMON VENT DIAMETER</b><br>(If a size is not available use the next larger size.) |                   |    |    |    |     |

THE ABOVE ILLUSTRATIONS AND TABLE OF VENT SIZES FOR COMMON VENTING OF MULTIPLE HEATERS ARE IN ACCORDANCE WITH THE NATIONAL FUEL GAS CODE ANSI Z223.1-LATEST EDITION, NFPA 54-LATEST EDITION, EQUIPMENT VOLUME OF 1988 ASHRAE HANDBOOK, CURRENT CAN/CGA-B149.1/2-M86 INSTALLATION CODE, AND AGA PUBLICATION NO. 10M5.85 2.5-2 ON FUNDAMENTALS OF GAS APPLIANCE VENTING AND VENTILATION-REVISED BUT ARE NOT A PART OF THE CSA CERTIFICATION.

- B. INDIRECT VENTING (UNVENTED HEATERS)** — This heater requires ventilation in the building to dilute the products of combustion and provide fresh air for efficient combustion. Where unvented heaters are used, gravity or mechanical means shall be provided to supply and exhaust at least 4 CFM per 1,000 Btu/hr input of installed heaters. Exhaust vents must be located at the highest point above and in the vicinity of the heaters, and the inlet vents must be located below the level of the heaters. An exhaust hood (Part #42924000) must be placed on the outlet collar of the draft inducer or on the existing 4" starting collar when used unvented and **must be mounted only in an upright position and directed towards the reflector body as shown.**



## 18.0) AIR FOR COMBUSTION

If indoor combustion air is to be supplied for a tightly enclosed area, one square inch of free area opening shall be provided below the heater for each 1,000 Btu/hr of heater input. When outside air is used, the opening below the heater shall be one square inch of free area for each 4,000 Btu/hr of heater input. In contaminated atmospheres or high humidity areas, optional outside air for combustion is recommended. Adequate clearances around the air inlet screen must be maintained at all times. In larger open areas of buildings, infiltration normally is adequate to provide air for combustion.

### 18.1) DIRECT OUTSIDE AIR FOR COMBUSTION



Outside combustion air should be supplied directly to the heater when the building is subject to negative pressure, or when contaminants or high humidity are present in the building air. These contaminants include paints, solvents, corrosive vapors or any other foreign particles that may cause damage to the heater or result in poor combustion.

Outside combustion air can be brought directly to the heater by a 6" diameter duct less than 50 ft. long or equivalent. This is attached to the 6" diameter starting collar. The starting collar is fitted to the top of the control box cabinet **after first removing and discarding the perforated cover.** An approved vent cap must be placed directly on the end of the outside combustion air inlet pipe. The combustion air inlet should be not less than 3 ft. (0.9m), either vertically or horizontally, from the flue vent termination. The air intake terminal must be located not less than 1 ft. (30cm) above grade. It is good installation practice to supply combustion air from the same pressure zone as the vent outlet. Avoid bringing combustion air to the heater from an attic space. There is no guarantee that adequate combustion air will be supplied.


If the heater is installed less than 2 ft. from the ceiling, a flexible transition section (e.g., flexible aluminum duct) must be provided to allow for expansion/contraction of straight tube heaters (SIS Series).

In colder climates, where necessary, insulate the outside combustion air duct. Avoid locating the outside combustion air duct directly above the control box. Provide a capped cleanout T as necessary. In high humidity applications, the control box should be sealed with silicone sealer.

In **multiple heater applications**, the combustion air intake may be ducted individually or common ducted in the same configuration as shown for venting in Section 17.0). For combustion air intake duct sizing, please refer to the **Vent Sizing Table** and use the diameter indicated, based on the number of heaters per duct.



## 19.0) LIGHTING AND SHUTDOWN INSTRUCTIONS


| ⚠ WARNING                                                                         |                                                                                   |                                                                                                                                                                                                                                                                 |
|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|  |  | <p><b>FIRE AND EXPLOSION HAZARD</b></p> <p>Never operate the heater with the access panel open or removed.</p> <p>The access panel must be closed tightly during operation.</p> <p>Failure to do so may result in death, serious injury or property damage.</p> |

1. Turn on the gas and electrical supply. Rotate the gas valve knob counter-clockwise ⤿ to the "ON" position.
2. Set the thermostat to call for heat. The blower motor will energize.
3. Ignition should occur after the 30-second air pre-purge.
4. If ignition fails, the unit will spark for approximately 21 seconds and go into safety lockout. Turn the thermostat (power) off for 60 seconds to take the system out of lockout.
5. If the heater does not light, manually reset the thermostat or shut off power completely for 5 minutes before attempting to relight.
6. To permanently shut down the heater, rotate the gas valve knob clockwise ⤿ to the "OFF" position and turn off the gas and electrical supply.

**NOTE:** The lighting and shutdown instructions are also shown on the permanent nameplate label attached to the heater control box.





## 20.0) SEQUENCE OF OPERATION

The chart below shows the sequence of operation for the normal operating cycle.





If the flame is not sensed during sequence T3 then the burner will automatically begin ignition sequence T2. If the flame is not re-established the heater will go to lockout.

## 21.0) CONTROL COMPONENT LOCATION



SIS/SIU 50-75 Models




SIS/SIU 100-175 Models

|   |                         |         |                   |         |                       |
|---|-------------------------|---------|-------------------|---------|-----------------------|
| 1 | Cabinet Assembly        | 7       | Restrainer Nipple | 13, 13a | Main Burner           |
| 2 | Air Inlet Plate         | 8       | Terminal Block    | 14, 14a | Burner Clamp          |
| 3 | Sight Glass             | 9       | Gas Valve         | 15, 15a | Ignition Cable        |
| 4 | Monitoring Light, Red   | 10      | Nipple            | 16      | Spark Electrode       |
| 5 | Monitoring Light, Amber | 11      | Coupling          | 17      | Spark Ignition Module |
| 6 | Access Panel            | 12, 12a | Orifice           | 18      | Sight Glass           |

**NOTE: Access panel only opens to 90°.**



## 22.0) CLEANING AND ANNUAL MAINTENANCE

| <b>⚠ WARNING</b>                                                                  |                                                                                   |                                                                                                                                                                                 |
|-----------------------------------------------------------------------------------|-----------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
|  |  | <b>ELECTRIC SHOCK &amp; EXPLOSION HAZARD</b><br><br>Disconnect electrical power and gas supply before servicing.<br><br>Failure to do so may result in death or serious injury. |


This heater must be cleaned and serviced annually by a qualified contractor before the start of each heating season and at any time excessive accumulation of dust and dirt is observed. Maximum heating efficiency and clean combustion will be maintained by keeping the heater clean.

The contractor shall check the following during periodic maintenance.


- **Clearances to combustibles:** Check that clearances are being maintained. Make sure there are no flammable objects, liquids or vapors near the heater. See also Section 4.0).
- **Reflectors:** Reflectors should be kept clean, at a minimum blow off the reflectors. (Dirty reflectors may reduce heat output).
- **Heat exchanger tubes:** Inspect the heat exchanger tubes to make sure they are not cracked, sagging or showing signs of fatigue.
- **Combustion air intake:** Disconnect combustion air intake from the control box and inspect internally using a flashlight to make sure no foreign material has collected in the tubes and that there is no obstruction around the air intake openings. Clean any foreign materials. Inspect any joints to make sure they are completely sealed. See also Section 18.0).
- **Venting System:** Disconnect vent pipe and inspect internally using a flashlight to make sure no foreign material has collected in the pipes. Check the external vent cap and make sure that there is no obstruction around the exhaust openings. Clean any foreign materials. Inspect any joints to make sure they are completely sealed. See also Section 17.0).
- **Gas lines:** Make sure that the gas lines are not leaking. Check the gas connection to the heater for any signs of damage, fatigue or corrosion. If there are any signs of damage to the gas connection or leaks found in the gas piping, immediately stop using the heater until the gas pipe and connections have been repaired or replaced. Check that the gas lines are not bearing the weight of the heater. See also Section 14.0).
- **Control Box:** In order to extend the longevity of the heater, the heat exchanger tube and the burner must be level. Check that the control box is level; use the turnbuckle on the burner suspension eyebolt to adjust the level of the burner. See also Section 9.0).
- **Blower wheel and housing:** Check that the blower wheel spins freely, blow out any dust or dirt with compressed air.
- **Electrode condition:** Visually check that the electrode gap is maintained at 3/16" and that the tips of the spark electrode are free from deposits. Clean off any deposits. Check that the electrode ceramic is free from cracks. See Section 24.1).
- **Suspension system:** Check that the suspension system is holding the heater level. Make sure that the heater is hanging securely, look for any evidence where the heater may have been hit accidentally and tighten any loose hanging points. Check that S hooks are closed. Check that there is no evidence of wear on the chain at the connection to the heater and at the ceiling.
- **Main Burner and Orifice:** Check the Main burner and orifice; remove any dirt or debris including spider webs. See Section 24.1).

## 23.0) TROUBLESHOOTING GUIDE







Troubleshooting continued from the previous page.



Troubleshooting continued from the previous page.





Troubleshooting continued from the page before last.



## 24.0) REPLACING PARTS

### ⚠ WARNING



#### ELECTRIC SHOCK & EXPLOSION HAZARD




Disconnect electrical power and gas supply before servicing.

Failure to do so may result in death or serious injury.

Only use genuine SunStar replacement parts. Parts are available from the factory for replacement by a licensed person. Refer to the Replacement Parts Guide in Section 26.0) for all replacement parts.


## 24.1) REMOVING SPARK ELECTRODE

The main burner can be inspected without removing the burner housing from the heat exchanger tube.




1. Disconnect electrical supply and open access panel.
2. Pull out the ignition cable hooked to spark electrode.
3. Remove two mounting screws.
4. Take out the spark electrode. Check that the spark gap is 3/16".
5. Check spark electrode. Spark electrode should be clean and free from debris.
6. Check ceramic on the spark electrode. It should be free from cracks.

## 24.2) REMOVING MAIN BURNER AND GAS VALVE



1. Disconnect electrical supply and gas connection at the restrainer nipple.
2. Open the access panel and disconnect the wires from gas valve.
3. Remove the burner clamp and screws.
4. Remove the burner and gas valve assembly from the cabinet.
5. Unscrew the burner from the manifold.
6. Check the orifice. If the gas valve is to be replaced, the pipe joint compounds must be resistant to the action of liquefied petroleum gases.

## 24.3) AIR SWITCH PRESSURE CHECK



1. Open hinged access panel.
2. Add tubing to connect the air switch with the connector tee and the existing tubing.
3. Connect plastic tubing of a digital or inclined water manometer with a 0-2" scale onto the connector tees.
4. Turn heater on and wait until blower motor is activated.
5. Observe air pressure from manometer. This should be higher than the set point 0.42" W.C. for correct operation.

**All pressures are with the heater in operation for at least 15 minutes.**

## 24.4) IGNITION SYSTEM CHECKS

### TO CHECK IGNITION CABLE.

- a. Make sure that the ignition cable does not touch any metal surface.
- b. Make sure that connections to the stud terminal and the igniter/sensor are clean and tight.
- c. Make sure that the ignition cable provides good electrical continuity.

### TO CHECK IGNITION SYSTEM GROUNDING.

(Nuisance shutdowns are often caused by a poor or erratic ground.) A common ground is required for the module, igniter, flame sensor and main burner.

- a. Check for good metal-to-metal contact between the igniter bracket and the main burner.
- b. Check the ground lead from the GND (BURNER) terminal on the module to the igniter bracket. Make sure connections are clean and tight. If the wire is damaged or deteriorated, replace it.
- c. Replace igniter/sensor with factory replacement part if insulator is cracked.

### TO CHECK SPARK IGNITION CIRCUIT.

**▲ WARNING:** The ignition circuit generates a 20,000 Volt open circuit and electrical shock can result.

- a. Check ignition cable.
- b. Check external fuse located inside the draft inducer junction box.
- c. Verify power (24V) at module input terminals and output terminal to gas valve.
- d. Replace spark module if fuse and power are OK.

## IGNITION MODULE DIAGNOSTICS (Fenwal #35-6087J1-034 module only)


The **LED** located on the ignition module will flash **ON** for  $\frac{1}{4}$  second, then **OFF** for  $\frac{1}{4}$  second during a fault condition. The pause between fault codes is 3 seconds.

| LED Indication | Error Mode             |
|----------------|------------------------|
| Steady On      | Internal Control Fault |
| 2 Flashes      | Flame Sense Fault      |
| 3 Flashes      | Ignition Lockout       |

## TO CHECK FLAME SENSOR CIRCUIT (Fenwal #35-6087J1-034 module only)

The flame current is the current that passes through the flame from the sensor to the ground. The minimum flame current necessary to keep the system from lockout is **0.7** micro-amps.

- To measure the flame current, connect an analog DC micro-ammeter to the **FC-** and **FC+** terminals per diagram. The meter should read **0.7** micro-amps or higher when the burner is running full on.
- If the meter reads below **zero**, the meter leads are reversed. Disconnect power and reconnect the meter leads for proper polarity.
- Remove micro-ammeter. Return system to normal operation.



Ignition Module - Alternate  
(Fenwal #35-6087J1-034)

## 24.5) MOTOR AND BLOWER WHEEL CHECK

If draft inducer motor fails to run:

- Check power supply to junction box.
- Check for loose or broken motor lead wire.
- Check to see that blower wheel turns freely and is not rubbing housing. Blower wheel may have worked loose from shaft and jammed against housing.
- Check for blower wheel damage; replace if necessary. If no damage, readjust blower wheel on shaft & retighten set screw.
- If all above does not correct, replace motor.

## 25.0) INSTALLATION DATA

Date of Installation: \_\_\_\_\_ # of Heaters in System: \_\_\_\_\_

Serial No. \_\_\_\_\_

Model: **SIS or SIU** \_\_\_\_\_


N = Natural Gas  
L = Propane Gas




## 26.0) REPLACEMENT PARTS GUIDE

| DRAFT INDUCER COMPONENTS |          |                                               |
|--------------------------|----------|-----------------------------------------------|
| Item No.                 | Part No. | Description                                   |
| 1                        | 42917000 | Draft Inducer Assembly                        |
| 1a                       | 42928000 | Motor Replacement Kit                         |
| 3                        | 03723000 | Blower Wheel, Revcor                          |
| 4                        | 03988120 | Plastic Vacuum Air Tube, 12" long             |
| 5                        | 42739010 | Blower Housing Sub-Assembly                   |
| 6                        | 42740000 | Motor Plate                                   |
| 7                        | 42742000 | Sensing Tube Bracket                          |
| 8                        | 42744000 | Sensing Tube, Draft Inducer                   |
| 9                        | 30347000 | Motor Spacer (4 per motor)                    |
| 10                       | 03868010 | 3/8" Connector                                |
| 11                       | 42837050 | Air Switch Kit, set @0.37" W.C., #NS2-0306-00 |
| 13                       | 30267000 | 1/2" Knockout Plug                            |
| 14                       | 30279000 | Transformer                                   |
| 15                       | 30281000 | Terminal Block, EK-204                        |
| 16                       | 30330000 | Terminal Block, TFB-323                       |
| 16a                      | 30202000 | Fuse, 2A 250V                                 |
| 17                       | 42709000 | Terminal Block Shield                         |
| 18                       | 30220010 | Monitoring Light, Green                       |
| 19                       | 02175050 | Strain Relief                                 |
| 21                       | 42909000 | Junction Box                                  |
| 22                       | 42910000 | Junction Box Cover                            |
| 23                       | 42911000 | Junction Box Support Bracket                  |
| 24                       | 42923000 | SJO Cable Assembly                            |
| 25                       | 03721000 | Motor                                         |
| 27                       | 43221000 | Draft Inducer Gasket                          |
| 30                       | 42741030 | Restrictor Plate, 1-1/8" I.D. (50M Btu/hr)    |
| 32                       | 42741010 | Restrictor Plate, 1-7/16" I.D. (75M Btu/hr)   |
| 34                       | 42741060 | Restrictor Plate, 1-5/8" I.D. (100M Btu/hr)   |
| 36                       | 42741080 | Restrictor Plate, 1-7/8" I.D. (125M Btu/hr)   |
| 37                       | 42741090 | Restrictor Plate, 2-1/32" I.D. (150M Btu/hr)  |
| 38                       | 42741100 | Restrictor Plate, 2-1/4" I.D. (175M Btu/hr)   |
| 40                       | 40504020 | Starting Collar, 4"                           |

| Labels / Manual |          |                         |      |
|-----------------|----------|-------------------------|------|
| Item No.        | Part No. | Description             | Qty. |
| 41              | 42874000 | Label, Wire Diagram     | 1    |
| 42              | 42922020 | Label, Sidewall Venting | 1    |




## DRAFT INDUCER COMPONENTS




| CONTROL COMPONENTS |          |                                                                |
|--------------------|----------|----------------------------------------------------------------|
| Item No.           | Part No. | Description                                                    |
| 10                 | 03868010 | 3/8" Connector                                                 |
| 28                 | 42874000 | Connection Wire Diagram (not shown)                            |
| 41                 | 30295000 | Electrode PSE-GF1 (Igniter/Sensor)                             |
| 42                 | 30314120 | Ignition Cable, 14" long                                       |
| 43                 | 30324000 | Terminal Block, EK-104                                         |
| 44                 | 30632060 | Spark Module – Fenwal #35-608711-034                           |
| 45                 | 42398060 | Monitoring Light, Red                                          |
| 46                 | 42398050 | Monitoring Light, Amber                                        |
| 47                 | 42447000 | Sight Glass                                                    |
| 51                 | 30333070 | Valve, VR8205P-2408 @3.5" W.C. (Natural Gas)                   |
| 52                 | 30333080 | Valve, VR8205P-2416 @10" W.C. (Propane Gas)                    |
| 53                 | 42757010 | Restrainer Nipple, 4" long                                     |
| 54                 | 42885000 | Spark Module Shield                                            |
| 55                 | 42887100 | Burner Clamp                                                   |
| 56                 | 42890010 | Burner Assembly                                                |
| 57                 | 42899100 | Burner Bracket Sub-Assembly                                    |
| 58                 | 42888000 | Electrode Bracket                                              |
| 59                 | 42893000 | Air Inlet Plate (Perforated)                                   |
| 60                 | 42905000 | Access Panel                                                   |
| 61                 | 42906100 | Cabinet Assembly (for offset burner)                           |
| 62                 | 42889000 | Orifice Fitting & Test Gauge Connection                        |
| 63                 | 03258xxx | Orifice for 100M–175M Btu/hr (State Model & Gas Type for Size) |
| 67                 | 03540090 | Coupling, ½"                                                   |
| 68                 | 42701000 | Orifice Fitting & Test Gauge Connection                        |
| 69                 | 03259xxx | Orifice for 50M-75M Btu/hr (State Model & Gas Type for Size)   |
| 70                 | 42700000 | Burner                                                         |
| 71                 | 43169000 | Burner Clamp                                                   |
| 72                 | 43172100 | Burner Bracket Sub-assembly                                    |
| 73                 | 43170000 | Electrode Bracket                                              |
| 74                 | 03333140 | Nipple, ½"x4" long                                             |

| Labels / Manual |          |                                                     |      |
|-----------------|----------|-----------------------------------------------------|------|
| Item No.        | Part No. | Description                                         | Qty. |
| 64              | 43343310 | Installation and Operation Instructions (not shown) | 1    |
| 75              | 42785000 | Label, Wire Diagram (ladder)                        | 1    |
| 76              | 42874000 | Label, Wire Diagram                                 | 1    |
| 77              | 42875000 | Label, Warning                                      | 1    |
| 78              | 43269000 | Label, 24V Supply                                   | 1    |
| 79              | 43270000 | Label, Terminal ID                                  | 1    |
| 80              | 42013010 | Label, "SunStar" Logo                               | 1    |
| 81              | 42848010 | Label, "SunStar" Nameplate                          | 1    |
| 82              | 43344010 | Label, Clearance to Combustibles                    | 1    |
| 83              | 43344050 | Label, Gas Connector Warning                        | 1    |



| BODY COMPONENTS: SIS/U 50-175                         |          |                                                                                        |
|-------------------------------------------------------|----------|----------------------------------------------------------------------------------------|
| Item No.                                              | Part No. | Description                                                                            |
| 1                                                     | 02266010 | Reflector Speed Clip                                                                   |
| 2                                                     | 43980010 | Wire Hanger                                                                            |
| 3                                                     | 42873000 | "U" Bolt Clamp, 4" OD Tube                                                             |
| 3a                                                    | 02127110 | 5/16-18 Hex Nut (2 per "U" Bolt)                                                       |
| 4                                                     | 43318000 | Tube Support/Hanger Bracket, 13"                                                       |
| 5                                                     | 43319050 | Reflector, 4'-11½" long (5' section only; 1 per 5 ft. body section)                    |
| 6                                                     | 43319100 | Reflector, 9'-11½" long (10' section only; 1 per 10 ft. body section)                  |
| 7                                                     | 43320000 | End Reflector                                                                          |
| 8                                                     | 43342000 | Corner Reflector Package                                                               |
| 9                                                     | 42921000 | Tube Flange Gasket                                                                     |
| 10*                                                   | 44028030 | 10' Tube Assembly Kit, 4" OD, ALC steel with one 24-hole flange (start tube)           |
| 11                                                    | 44028100 | 10' Tube Assembly Kit, 4" OD, HR steel without flanges (extension tube & exhaust tube) |
| 12                                                    | 44028120 | 5' Tube Assembly Kit, 4" OD, HR steel without flanges (extension tube & exhaust tube)  |
| 13                                                    | 43208010 | 4" O.D. Elbow Package                                                                  |
| 14                                                    | 02189020 | #10 x ½" Self-Drilling Screw (2 per coupling)                                          |
| 15                                                    | 30462980 | 4" OD Tube Compression Coupling w/bolts                                                |
| 16                                                    | 43208020 | 4" OD U-Bend (Required for SIU Only)                                                   |
| 17                                                    | 43488000 | U-Bend Reflector (SIU Option)                                                          |
| 18                                                    | 44015251 | Tube Flange Assembly (with 1/4-20 x 1" screw)                                          |
| * Required on all models for mounting of control box. |          | ALC = Heat Treated, Aluminized Steel<br>HR = Hot Rolled Steel                          |



**Note:**

- 1) Screws, Nuts and Washers are standard hardware items and can be purchased at any local hardware store.
- 2) Please order by PART NUMBER – not by Item Number.
- 3) Replacement Part Prices are available when ordering.
- 4) Please refer to complete Model Number when ordering.

ALL ILLUSTRATIONS ARE INTENDED TO GIVE THE GENERAL IMPRESSION OF UNITS ONLY. OTHER COMBINATIONS OF 5 FT. AND 10 FT. SECTIONS, AND ONES WITH OR WITHOUT THE ELBOW PACKAGE ARE POSSIBLE. PLEASE CONSULT WITH YOUR SUNSTAR SALES REPRESENTATIVE. WE RESERVE THE RIGHT TO ALTER ANY SPECIFICATION WITHOUT NOTICE. A